

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814
0747288586 0488571866
admin@parkerselectricalnq.com.au
parkerselectricalnq.com.au
LIC No 86114



5 September 2019

Gromac Quarry NQ
Barabon Quarry

Test and Tag Office

Date	Item	Item No	Plant/Location	Test	Re-Test
05/09/2019	Zip Instant hot water	BB10	Office	OK	05/09/2024
05/09/2019	Kelvinator AC unit	BB11	Office	OK	05/09/2024
05/09/2019	Power supply UHF	BB13	Office	OK	05/09/2024
05/09/2019	15A Extension Lead	BB15	Office	OK	05/09/2024
05/09/2019	15A Extension Lead	BB17	Office	OK	05/09/2024
05/09/2019	Kettle	BB18	Office	OK	05/09/2024
05/09/2019	Diesel Bowser	BB22	Office	OK	05/09/2024
05/09/2019	Brother Printer	BB23	Office	OK	05/09/2024
05/09/2019	GME Charger	BB24	Office	OK	05/09/2024

All extension Leads, plug in devices have been Tested and tagged by a qualified electrician as per table above, there were no faults found and all leads and plug in devices are in good working order. The next due test date is 5 September 2024.

Gary Parker