

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

0747288586 0488571866

admin@parkerselectricalnq.com.au

parkerselectricalnq.com.au

LIC No 77932



11/05/2019

Gromac Quarry NQ

Barabon Quarry

Test and Tag

Date	Item	Item No	Plant/Location	Test	Re-Test
11/05/2019	10A Extension Lead	BB1	MP904	OK	11/08/2019
11/05/2019	Oranga Pump	BB2	MP904	OK	11/08/2019
11/05/2019	Conveyer 4	BB3	MP904	OK	11/08/2019
11/05/2019	Conveyer 5	BB4	MP904	OK	11/08/2019
11/05/2019	Extension Lead	BB5	Service truck	OK	11/08/2019
11/05/2019	Hitachi Grinder	BB6	Service Truck	OK	11/08/2019
11/05/2019	15A extension lead	BB7	Office store container	OK	11/08/2019
11/05/2019	Air Compressor	BB9	Service container	Ok	11/08/2019
11/05/2019	Zip Instant hot water	BB10	Office	OK	11/08/2019
11/05/2019	Kelvinator AC unit	BB11	Office	OK	11/08/2019
11/05/2019	Power supply UHF	BB13	Office	OK	11/08/2019
11/05/2019	15A Extension Lead	BB15	Office	OK	11/08/2019
11/05/2019	15A Extension Lead	BB17	Office	OK	11/08/2019
11/05/2019	Kettle	BB18	Office	OK	11/08/2019
11/05/2019	Conveyer	BB19	Pr coat plant	OK	11/08/2019
11/05/2019	Light	BB20	GN814	OK	11/08/2019
11/05/2019	Conveyer	BB21	MP948	OK	11/08/2019
11/05/2019	Diesel Bowser	BB22	Office	OK	11/08/2019
11/05/2019	Brother Printer	BB23	Office	OK	11/08/2019
11/05/2019	GME Charger	BB24	Office	OK	11/08/2019
11/05/2019	Boss Welder	BB25	Service Truck	OK	11/08/2019
11/05/2019	Conveyer	BB26	Pr Coat Plant	OK	11/08/2019

Earth Leakage Devices

Date	Plant	Item No	Plant/Location	Test	Re-Test
11/05/2019	GN814		Pit Crusher Generator Main	10ms	11/08/2019
11/05/2019	GN814		Pit Crusher Generator outlets	15ms	11/08/2019
11/05/2019	GN825		Pre-coat Generator Main	21ms	11/08/2019
11/05/2019	Gn825		Pre-Coat Generator Outlets	25ms	11/08/2019
11/05/2019	Oil Container	2	Office	10ms	11/08/2019
11/05/2019	Oil Container	3	Office	16ms	11/08/2019
11/05/2019	Post outlet 1	1	Office	9ms	11/08/2019
11/05/2019	Post Outlet 2	2	Office	8ms	11/08/2019
11/05/2019	Store Container	1	Office	12ms	11/08/2019
11/05/2019	Office sub board	1	Office	8ms	11/08/2019
11/05/2019	Office sub board	2	Office	7.1ms	11/08/2019
11/05/2019	Office sub board	3	Office	17ms	11/08/2019
11/05/2019	Office sub board	4	Office	8ms	11/08/2019

All extension Leads, plug in devices and earth leakage devices have been Tested and tagged by a qualified electrician as per table above the next due test date is 11/08/2019 for test & tag and the next test date for earth leakage devices is 11/08/2019.

Gary Parker

