

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

0747288586 0488571866

admin@parkerselectricalng.com.au

parkerselectricalng.com.au

LIC No 77932



15/05/2018

Gromac Quarry NQ

Barabon Quarry

Test and Tag

[illegible]

Earth Leakage Devices

Date	Plant	Item No	Plant/Location	Test	Re-Test
15/05/2018	GN803		Pit Crusher Generator Main	10ms	15/08/2018
15/05/2018	GN803		Pit Crusher Generator outlets	15ms	15/08/2018
15/05/2018	GN825		Pre-coat Generator Main	21ms	15/08/2018
15/05/2018	Gn825		Pre-Coat Generator Outlets	25ms	15/08/2018
15/05/2018	Oil Container	2	Office	10ms	15/08/2018
15/05/2018	Oil Container	3	Office	16ms	15/08/2018
15/05/2018	Post outlet 1	1	Office	9ms	15/08/2018
15/05/2018	Post Outlet 2	2	Office	8ms	15/08/2018
15/05/2018	Store Container	1	Office	12ms	15/08/2018
15/05/2018	Office sub board	1	Office	8ms	15/08/2018
15/05/2018	Office sub board	2	Office	7.1ms	15/08/2018
15/05/2018	Office sub board	3	Office	17ms	15/08/2018
15/05/2018	Office sub board	4	Office	8ms	15/08/2018

All extension Leads, plug in devices and earth leakage devices have been Tested and tagged by a qualified electrician as per table above the next due test date is 15/05/2018 for test & tag and the next test date for earth leakage devices is 21/08/2018.

Gary Parker

