

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

0747288586 0488571866

admin@parkerselectricalnq.com.au

parkerselectricalnq.com.au

LIC No 86114



12 August 2019

Gromac Quarrrtes NQ

Charters Towers

RCD TEST Work Shop

Date	Plant/Location	Test	Pas/Fail	Re-Test
12/08/19	SW Board 1 RCD 1	20ms	P	12/02/20
12/08/19	SW Board 1 RCD 2	17ms	P	12/02/20
12/08/19	SW Board 1 RCD 3	10ms	P	12/02/20
12/08/19	SW Board 1 RCD 4	5ms	P	12/02/20
12/08/19	SW Board 2 RCD 1	12ms	P	12/02/20
12/08/19	SW Board 2 RCD 2	25ms	P	12/02/20
12/08/19	WS Generator RCD 1	5ms	P	12/02/20
12/08/19	WS Generator RCD 2	12ms	P	12/02/20
12/08/19	WS Generator RCD 3	19MS	P	12/02/20
12/08/19	WS Generator RCD 4	14MS	P	12/02/20

RCD TEST Main Plant (Crusher)

Date	Plant/Location	Test	Pas/Fail	Re-Test
12/08/19	Generator GN809	22ms	P	12/02/20
12/08/19	Switch room RCD 1	1.5ms	P	12/02/20
12/08/19	Switch room RCD 2	13ms	P	12/02/20
12/08/19	Crusher Switch room RCD 1	15ms	P	12/02/20
12/08/19	Crusher Switch room RCD 2	25ms	P	12/02/20

RCD TEST Office

Date	Plant/Location	Test	Pas/Fail	Re-Test
12/08/19	Switchboard 1 RCD	18ms	P	12/02/20
12/08/19	Switchboard 2 RCD	11ms	P	12/02/20

All earth leakage devices have been tested and tagged by a qualified electrician as per table above the next due test date is 12 February 2020.

Gary Parker