

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814
0747288586 0488571866
admin@parkerselectricalnq.com.au
parkerselectricalnq.com.au
LIC No 77932



21/6/2018

Gromac Quarrrtes NQ
Charters Towers

Test Results for test and tag and RCD's in the crusher and office at Charters Towers.

Test and Tag Work Shop

Date	Item	Item No	Plant/Location	Test	Re-Test
21/06/18	10W LED Light	1	Bowser	OK	21/09/18
21/06/18	Yellow Ex Lead	4	Work Shop	OK	21/09/18
21/06/18	32A 3ph Lead	5	Work Shop	OK	21/09/18
21/06/18	10W LED Light	6	Work Shop	OK	21/09/18
21/06/18	Bench Grinder	7	Work Shop	OK	21/09/18
21/06/18	Charger	8	Work Shop	OK	21/09/18
21/06/18	Press Drill	9	Work Shop	OK	21/09/18
21/06/18	Ex Lead	10	Work Shop	OK	21/09/18
21/06/18	pump	11	Work Shop	OK	21/09/18
21/06/18			Work Shop	OK	21/09/18
21/06/18	Air Compressor	13	Work Shop	OK	21/09/18
21/06/18	Fan	14	Work Shop	OK	21/09/18
21/06/18	Hitachi Drop saw	15	Work Shop	OK	21/09/18
21/06/18	3 Ph Welder	16	Work Shop	OK	21/09/18
21/06/18	Flood Light	17	Work Shop	OK	21/09/18
21/06/18	Yellow Ex Lead	18	Work Shop	OK	21/09/18

Test and Tag Crusher

Date	Item	Item No	Plant/Location	Test	Re-Test
21/6/18	Kalvinator air conditioner	19	Crusher control rm	OK	21/9/18
21/6/18	4 pack	20	Crusher control rm	OK	21/9/18
21/6/18	UHF power supply	21	Crusher control rm	OK	21/9/18
21/6/18	Ext. lead	22	Crusher switch rm	OK	21/9/18
21/6/18	Davies water pump	23	Crusher switch rm	OK	21/9/18

Test and Tag Office

Date	Item	Item No	Plant/Location	Test	Re-Test
21/6/18	Dell laptop	24	Office	OK	21/6/19
21/6/18	Dell monitor	25	Office	OK	21/6/19
21/6/18	Net gear router	26	Office	OK	21/6/19
21/6/18	Phone	27	Office	OK	21/6/19
21/6/18	Brother printer	28	Office	OK	21/6/19
21/6/18	UHF power supply	29	Office	OK	21/6/19
21/6/18	4 pack	30	Office	OK	21/6/19
21/6/18	4 pack	31	Office	OK	21/6/19
21/6/18	Ext. lead	32	Office	OK	21/6/19
21/6/18	UPS	33	Office	OK	21/6/19
21/6/18	4 pack	34	Office	OK	21/6/19
21/6/18	4 pack	35	Office	OK	21/6/19
21/6/18	Dell printer	36	Office	OK	21/6/19
21/6/18	Scales	37	Office	OK	21/6/19
21/6/18	Scales	38	Office	OK	21/6/19
21/6/18	4 pack	39	Office	OK	21/6/19
21/6/18	4 Pack	40	Office	OK	21/6/19
21/6/18	Fridge	41	Office	OK	21/6/19
21/6/18	Kalvinator AC	42	Office	OK	21/6/19
21/6/18	Ext. lead	43	Office	OK	21/6/19
21/6/18	LED light	44	Office	OK	21/6/19
21/6/18	Brother Printer	16	Office	OK	21/6/19
21/6/18	Dell Laptop	47	Office	OK	21/6/19
21/6/18	Sharp Microwave	48	Office	OK	21/6/19
21/6/18	Kettle	49	Office	OK	21/6/19

RCD TEST Work Shop

Date	Plant/Location	Test	Pas/Fail	Re-Test
21/6/18	SW Board 1 RCD 1	20ms	P	21/9/2018
21/6/18	SW Board 1 RCD 2	17ms	P	21/9/2018
21/6/18	SW Board 1 RCD 3	10ms	P	21/9/2018
21/6/18	SW Board 1 RCD 4	5ms	P	21/9/2018
21/6/18	SW Board 2 RCD 1	12ms	P	21/9/2018
21/6/18	SW Board 2 RCD 2	25ms	P	21/9/2018
21/6/18	WS Generator RCD 1	5ms	P	21/9/2018
21/6/18	WS Generator RCD 2	12ms	P	21/9/2018
21/6/18	WS Generator RCD 3	19MS	P	21/9/2018
21/6/18	WS Generator RCD 4	14MS	P	21/9/2018

RCD TEST Main Plant (Crusher)

Date	Plant/Location	Test	Pas/Fail	Re-Test
21/6/18	Generator GN809	22ms	P	21/9/18
21/6/18	Switch room RCD 1	1.5ms	P	21/9/18
21/6/18	Switch room RCD 2	13ms	P	21/9/18
21/6/18	Crusher Switch room RCD 1	15ms	P	21/9/18
21/6/18	Crusher Switch room RCD 2	25ms	P	21/9/18

RCD TEST Office

Date	Plant/Location	Test	Pas/Fail	Re-Test
21/6/18	Switchboard 1 RCD	18ms	P	21/9/18
21/6/18	Switchboard 2 RCD	11ms	P	21/9/18

Gary Parker

