

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814
0747288586 0488571866
admin@parkerselectricalnq.com.au
parkerselectricalnq.com.au
LIC No 77932



26/9/2018

Gromac Quarrrtes NQ
Plumtree Quarries
Flinders Hwy
Charters Towers, QLD 4820

Test Results for test and tag and RCD's in the crusher and office at Charters Towers.

Test and Tag Work Shop

Date	Item	Item No	Plant/Location	Test	Re-Test
26/09/18	10W LED Light	1	Bowser	OK	26/12/18
26/09/18	Kettle	2	Work Shop	OK	26/12/18
26/09/18	Yellow Ex Lead	4	Work Shop	OK	26/12/18
26/09/18	32A 3ph Lead	5	Work Shop	OK	26/12/18
26/09/18	10W LED Light	6	Work Shop	OK	26/12/18
26/09/18	Bench Grinder	7	Work Shop	OK	26/12/18
26/09/18	Charger	8	Work Shop	OK	26/12/18
26/09/18	Press Drill	9	Work Shop	OK	26/12/18
26/09/18	Ex Lead	10	Work Shop	OK	26/12/18
26/09/18	pump	11	Work Shop	OK	26/12/18
26/09/18			Work Shop	OK	26/12/18
26/09/18	Air Compressor	13	Work Shop	OK	26/12/18
26/09/18	Fan	14	Work Shop	OK	26/12/18
26/09/18	3 Ph Welder	16	Work Shop	OK	26/12/18
26/09/18	Flood Light	17	Work Shop	OK	26/12/18
26/09/18	Yellow Ex Lead	18	Work Shop	OK	26/12/18

Test and Tag Mobile Plant

Date	Item	Item No	Plant/Location	Test	Re-Test
26/09/18	Blue 15A Ex Lead	MP1	Service Truck	OK	26/12/18
26/09/18	Blue 15A Ex Lead	MP2	Service Truck	OK	26/12/18
26/09/18	Tig Welder	MP3	Service Truck	OK	26/12/18

Test and Tag Crusher

Date	Item	Item No	Plant/Location	Test	Re-Test
26/09/18	Kalvinator air conditioner	19	Crusher control rm	OK	26/12/18
26/09/18	4 pack	20	Crusher control rm	OK	26/12/18
26/09/18	UHF power supply	21	Crusher control rm	OK	26/12/18
26/09/18	Ext. lead	22	Crusher switch rm	OK	26/12/18
26/09/18	Davies water pump	23	Crusher switch rm	OK	26/12/18

Test and Tag Office

Date	Item	Item No	Plant/Location	Test	Re-Test
21/6/18	Dell laptop	24	Office	OK	21/6/19
21/6/18	Dell monitor	25	Office	OK	21/6/19
21/6/18	Net gear router	26	Office	OK	21/6/19
21/6/18	Phone	27	Office	OK	21/6/19
21/6/18	Brother printer	28	Office	OK	21/6/19
21/6/18	UHF power supply	29	Office	OK	21/6/19
21/6/18	4 pack	30	Office	OK	21/6/19
21/6/18	4 pack	31	Office	OK	21/6/19
21/6/18	Ext. lead	32	Office	OK	21/6/19
21/6/18	UPS	33	Office	OK	21/6/19
21/6/18	4 pack	34	Office	OK	21/6/19
21/6/18	4 pack	35	Office	OK	21/6/19
21/6/18	Dell printer	36	Office	OK	21/6/19
21/6/18	Scales	37	Office	OK	21/6/19
21/6/18	Scales	38	Office	OK	21/6/19
21/6/18	4 pack	39	Office	OK	21/6/19
21/6/18	4 Pack	40	Office	OK	21/6/19
21/6/18	Fridge	41	Office	OK	21/6/19
21/6/18	Kalvinator AC	42	Office	OK	21/6/19
21/6/18	Ext. lead	43	Office	OK	21/6/19
21/6/18	LED light	44	Office	OK	21/6/19
21/6/18	Brother Printer	16	Office	OK	21/6/19
21/6/18	Dell Laptop	47	Office	OK	21/6/19
21/6/18	Sharp Microwave	48	Office	OK	21/6/19
21/6/18	Kettle	49	Office	OK	21/6/19

RCD TEST Work Shop

Date	Plant/Location	Test	Pas/Fail	Re-Test
26/09/18	SW Board 1 RCD 1	20ms	P	26/12/18
26/09/18	SW Board 1 RCD 2	17ms	P	26/12/18
26/09/18	SW Board 1 RCD 3	10ms	P	26/12/18
26/09/18	SW Board 1 RCD 4	5ms	P	26/12/18
26/09/18	SW Board 2 RCD 1	12ms	P	26/12/18
26/09/18	SW Board 2 RCD 2	25ms	P	26/12/18
26/09/18	WS Generator RCD 1	5ms	P	26/12/18
26/09/18	WS Generator RCD 2	12ms	P	26/12/18
26/09/18	WS Generator RCD 3	19MS	P	26/12/18
26/09/18	WS Generator RCD 4	14MS	P	26/12/18

RCD TEST Main Plant (Crusher)

Date	Plant/Location	Test	Pas/Fail	Re-Test
26/09/18	Generator GN809	22ms	P	26/12/18
26/09/18	Crusher Switch room RCD 1	15ms	P	26/12/18
26/09/18	Crusher Switch room RCD 2	25ms	P	26/12/18

RCD TEST Office

Date	Plant/Location	Test	Pas/Fail	Re-Test
26/09/18	Switchboard 1 RCD	13ms	P	26/12/18
26/09/18	Switchboard 1 RCD	10ms	P	26/12/18
26/09/18	Switchboard 1 RCD	20ms	P	26/12/18
26/09/18	Switchboard 2 RCD	11ms	P	26/12/18

All extension Leads, plug in devices and earth leakage devices have been tested and tagged by a qualified electrician as per table above the next due test date is 26/12/2018 for test & tag and the next test date for earth leakage devices is 26/12/2018. Gary Parker

