

## PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

0747288586 0488571866

[admin@parkerselectricalnq.com.au](mailto:admin@parkerselectricalnq.com.au)

parkerselectricalnq.com.au

LIC No 77932



Date 14 May 2017

Gromac Quarries

Po Box 385

Thuringwa Central

QLD 4817

Attend Gromac Pinnacle Quarry Site in Townsville on the 13<sup>th</sup> of May 2017, performed diagnostics on MP965 Generator, tested all power, field and excitation windings, found windings windings to be within manufactures specifications, tested AVR card and found only half output, found correct feedback. Tested all operation of the plant and found no faults and that the load would be balanced, as most of the load is 3 phase motors.

On the 14<sup>th</sup> of May replaced AVR card, set card as manufacturer specifies, test and found good output then tested generator under load and found to have good operation. Test the load and found to with a good Balance between phases.

Gary Parker

A handwritten signature in black ink, appearing to read "Gary Parker". The signature is stylized and cursive.