

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

Ph 0747288586 0488571866

admin@parkerselectricalnq.com.au

<https://parkerselectricalnq.com.au>

LIC No 77932



Date 14/05/2019

Gromac Quarry NQ

Townsville Quarry

Townsville Pinnacle Quarry

Gumlow Rd

Pinnacles QLD 4815

Lanyard and E stops

Unit No	Descripton	E-Stop Count	Lanyard Count	Pass	Fail	Comments
GN 817	Cummins C250D5	1	nil	OK		
GN812	Cummins C820KVA	3	0	OK		
PNPC01	Pre Coat Plant	0	3	OK		Repair 1 Lanyard
CR01	Main Crusher	4	Nil	OK		
CR01	R/B Main Crusher	1	Nil	OK		
PUG 01	Pugmill	7	8	OK		
GN818	Perkins 500KVA Controller	2	0	OK		Replace 1 E Stop
MP909	Barmac	1	2	OK		Replace 1 Lanyard
mp923	Trackmasta 2153	4	6	OK		
MP935	Convayer	0	2	OK		
MP953	Kleeman Mobicone MCO13H	3	0	OK		
MP956	Precisionscreen MS65	5	0	OK		
MP957	Convayer	0	2	OK		
MP958	Convayer	0	2	OK		
MP 962	TS1542 Telestacker	1	2	OK		
MP973	Kleeman MCO13H	3	0	OK		

MP975	Kleeman MS23D	6	3	OK		
MP977	Convayer	0	2	OK		
MP978	Convayer	0	2	OK		
MP980	Convayer	0	2	OK		
MP985	Powerscreen Premiertrak 600	4	8	OK		
mp952	Precisionscreen MS50	5	0	OK		
	Feed Bin	0	2	OK		
	Green Convayer	0	2	OK		

All Test on E Stops and Lanyard have been commpleted and repairs made where needed.

Gary Parker

