

# PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

0747288586 0488571866

[admin@parkerselectricalnq.com.au](mailto:admin@parkerselectricalnq.com.au)

[parkerselectricalnq.com.au](http://parkerselectricalnq.com.au)

LIC No 86114



26 August 2019

Gromac Quarry NQ

Townsville Quarry

## Earth Leakage Devices

Date	Plant	Item No	Plant/Location	Test	Re-Test
26/08/2019	Pump/ power	1	Work shop	19.4ms	26/02/2019
26/08/2019	Power	2	Work shop	37ms	26/02/2019
26/08/2019	Fuel bowser	3	Work shop	43.6ms	26/02/2019
26/08/2019	32A 3 phase outlet	4	Work shop	17.5ms	26/02/2019
26/08/2019	32A 3 phase outlet	5	Work shop	128.5ms	26/02/2019
26/08/2019	50A 3 phase outlet	6	Work shop	10ms	26/02/2019
26/08/2019	32A 3 phase outlet	7	Work shop	18ms	26/02/2019
26/08/2019		8	Work shop	8ms	26/02/2019
26/08/2019					26/02/2019
26/08/2019	RCD	1	Smoko Room	7.1ms	26/02/2019
26/08/2019		2	PNCRO1	12ms	26/02/2019
26/08/2019		4	PNCRO1	11ms	26/02/2019
26/08/2019		6	PNCRO1	10ms	26/02/2019
26/08/2019		8	PNCRO1	15ms	26/02/2019
26/08/2019		15	PNCRO1	9ms	26/02/2019
26/08/2019		22	PNCRO1	10ms	26/02/2019
26/08/2019		24	PNCRO1	13ms	26/02/2019
26/08/2019			Main Feeder	20ms	26/02/2019
26/08/2019			Kobe Jaw	20ms	26/02/2019
26/08/2019					26/02/2019
26/08/2019		1	MP973	19.6ms	26/02/2019
26/08/2019		2	MP973	5.5ms	26/02/2019

26/08/2019	Not Used	3	MP973	18ms	26/02/2019
26/08/2019		1	MP953	44ms	26/02/2019
26/08/2019		2	MP953	55ms	26/02/2019
26/08/2019	Not Used	3	MP953	10ms	26/02/2019
26/08/2019		1	MP975	36.6ms	26/02/2019
26/08/2019	Not Used	2	MP975	16ms	26/02/2019
26/08/2019		1	MP962	22ms	26/02/2019
26/08/2019		2	MP962	12ms	26/02/2019
26/08/2019		1	MP939	9ms	26/02/2019
26/08/2019		1	6N812	17ms	26/02/2019
26/08/2019		2	6N812	16.4ms	26/02/2019
26/08/2019		3	6N812	35ms	26/02/2019
26/08/2019		4	6N812	18ms	26/02/2019
26/08/2019		5	6N812	23ms	26/02/2019
26/08/2019		1	6N817	28ms	26/02/2019
26/08/2019	AC	1	CNB Room	17ms	26/02/2019
26/08/2019	Power	2	CNB Room	23ms	26/02/2019
26/08/2019	Lights	3	CNB Room	15ms	26/02/2019
26/08/2019		4	Pugmill	24ms	26/02/2019
26/08/2019		44	Pugmill	28ms	26/02/2019
26/08/2019		46	Pugmill	29ms	26/02/2019
26/08/2019		48	Pugmill	12ms	26/02/2019
26/08/2019		50	Pugmill	24ms	26/02/2019
26/08/2019		3	Pugmill	20ms	26/02/2019
26/08/2019		4	Pugmill	21ms	26/02/2019
26/08/2019		5	Pugmill	18ms	26/02/2019
26/08/2019	Upstairs	3	Pugmill	19ms	26/02/2019
26/08/2019	Upstairs	4	Pugmill	20ms	26/02/2019
26/08/2019	Upstairs	5	Pugmill	23ms	26/02/2019
26/08/2019			Wash plant	7.4ms	26/02/2019
26/08/2019			Wash plant	34.8ms	26/02/2019
26/08/2019					26/02/2019
26/08/2019		1	Office	15.2ms	26/02/2019
26/08/2019		2	Office	16.1ms	26/02/2019
26/08/2019		3	Office	13.0ms	26/02/2019
26/08/2019					26/02/2019
26/08/2019		1	Accommodation	15ms	26/02/2019
26/08/2019			Accommodation	12ms	26/02/2019
26/08/2019			Accommodation	8.8ms	26/02/2019
26/08/2019			Accommodation	19ms	26/02/2019
26/08/2019					26/02/2019
26/08/2019		1	Donga	8ms	26/02/2019
26/08/2019					26/02/2019

26/08/2019		1	Caravan	9ms	26/02/2019
26/08/2019		2	Caravan	10ms	26/02/2019

All RCD have been tested in accordance with the table above and will require retesting on the 26<sup>th</sup> February 2020.

Gary Parker

