

PARKER'S ELECTRICAL NQ

43 Canara St Cranbrook Q 4814

0747288586 0488571866

admin@parkerselectricalnq.com.au

parkerselectricalnq.com.au

LIC No 77932



26/03/2019

Gromac Quarry NQ

Townsville Quarry

Earth Leakage Devices Pin Boily Shed

Date	Plant	Circuit No	Plant/Location	Test	Re-Test
26/3/2019	Switchboard	2	Pin Boily Shed	7ms	26/03/2019
26/3/2019	Switchboard	7	Pin Boily Shed	5ms	26/03/2019
26/3/2019	Switchboard	12	Pin Boily Shed	8ms	26/03/2019
26/3/2019	Switchboard	17	Pin Boily Shed	5.2ms	26/03/2019
26/3/2019	Switchboard	21	Pin Boily Shed	6ms	26/03/2019
26/3/2019	Switchboard	22	Pin Boily Shed	4.8ms	26/03/2019
26/3/2019	Switchboard	23	Pin Boily Shed	5.7ms	26/03/2019
26/3/2019	Switchboard	24	Pin Boily Shed	4.3ms	26/03/2019
26/3/2019	Switchboard	25	Pin Boily Shed	6.1ms	26/03/2019
26/3/2019	Switchboard	26	Pin Boily Shed	5.1ms	26/03/2019
26/3/2019	Switchboard	27	Pin Boily Shed	7.2ms	26/03/2019
26/3/2019	Switchboard	28	Pin Boily Shed	6ms	26/03/2019
26/3/2019	Switchboard	29	Pin Boily Shed	8ms	26/03/2019
26/3/2019	Switchboard	30	Pin Boily Shed	7.1ms	26/03/2019

All electrical installation, this Certifies that the electrical installation, to the extent it is affected by the electrical work, has been tested to ensure that it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying under the Electrical Safety Regulation 2002 to the electrical installation.

Gary Parker